

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	LED Driver
Name and address of the applicant	Guangdong Done Power Technology Co.,Ltd. No.3-1&3-2, Kanglong 3rd Road, Henglan Town, Zhongshan, 528478 Guangdong, P.R. China
Name and address of the manufacturer	Guangdong Done Power Technology Co.,Ltd. No.3-1&3-2, Kanglong 3rd Road, Henglan Town, Zhongshan, 528478 Guangdong, P.R. China
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Guangdong Done Power Technology Co.,Ltd. No.3-1&3-2, Kanglong 3rd Road, Henglan Town, Zhongshan, 528478 Guangdong, P.R. China
Ratings and principal characteristics	Independent constant current LED driver, IP66 & IP67 AC Input : Refer to page 2; Class I DC Output: Refer to page 2
Trademark / Brand (if any)	DONE
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	1) DL-30W-V56DX-MXG, 2) DL-50W-V56DX-MXG, 3) DL-50W-V72DX-MXG, 4) DL-75W-V56DX-MXG
Additional information (if necessary may also be reported on page 2)	See additional page(s) for further Additional information. For model differences, refer to the test report.
A sample of the product was tested and found to be in conformity with	IEC 61347-2-13:2014+A1 IEC 61347-1:2015+A1
As shown in the Test Report Ref. No. which forms part of this Certificate	CN23U9C1 001

This CB Test Certificate is issued by the National Certification Body



Date: 2024-12-23

TÜV Rheinland Japan Ltd.
4-25-2 Kita-Yamata, Tsuzuki-ku
Yokohama 224-0021, Japan
Mail: info@jpn.tuv.com

Signature:


Martin Wang

Additional information :

AC Input :

- 1) 120-240/277V, 50/60Hz, 0.35A
- 2) 120-240/277V, 50/60Hz, 0.5A
- 3) 120-240/277V, 50/60Hz, 0.5A
- 4) 120-240/277V, 50/60Hz, 0.8A

DC Output:

- 1) 25-56V, 0.3-1.0A, 30W
- 2) 25-56V, 0.6-1.7A, 50W
- 3) 36-72V, 0.5-1.05A, 50W
- 4) 25-56V, 0.85-2.1A, 75W



Date: 2024-12-23

Signature: as on page 1