

TANÚSÍTVÁNY

Certificate



Tanúsítvány szám *Certificate No.*
HN 69291275

Oldal *Page*
0001

Jegyzőkönyv szám *Test Report No.*
CN23M6OM 001

Kiadás dátuma *Date of Issue*
2024-07-10

Tanúsítvány Tulajdonos *Certificate Holder*
Guangdong Done Power Technology Co., Ltd.
No.3-1&3-2, Kanglong 3rd Road,
Henglan Town, Zhongshan, 528478
Guangdong, P.R. China

Gyártóhely *Manufacturing Plant*
Guangdong Done Power Technology Co., Ltd.
No.3-1&3-2, Kanglong 3rd Road,
Henglan Town, Zhongshan, 528478
Guangdong, P.R. China

Vizsgálati Jel *Test Mark*



Tanúsítás alapjául szolgáló előírások *Tested according to*
EN 61347-2-13:2014+A1
EN 61347-1:2015+A1
EN IEC 62384:2020

Tanúsított Termék (Termék azonosítás)
Certified Product (Product Identification)

Electronic controlgear for LED module (LED Driver)
Type Designation : 1) DL-50Z-58A-MAL, DL-50Z-58S-MAL
2) DL-60Z-58A-MAL, DL-60Z-58S-MAL
Rated Voltage : AC 100-277V, 50/60Hz
Rated Current : 1) 0.60A; 2) 0.77A
Degree of protection : IP65
Protection Class : Class I
Trade Mark : DONE

See details in the Annex of this certificate.

A tanúsítvány a fenti termék típusra vonatkozik. A tanúsítvány a TÜV Rheinland InterCert Kft. Vizsgálati, Ellenőrzési és Tanúsítási Szabályzatán alapszik. A tanúsított termék megfelel a fenti vizsgálati előírásoknak, a sorozatgyártása ellenőrzött. A fenti ENEC jel használatának joga engedélyezett a tanúsított terméken. Ezt az Engedélyt egy ENEC egyezményt aláíró testület adta ki. This certificate refers to the above mentioned product type. The certificate is based on the Testing, Inspection and Certification Regulation of TÜV Rheinland InterCert Kft. The certified product fulfils the above listed requirements and its manufacturing is subject to surveillance. The right to use the above ENEC mark is permitted on the certified product. This Licence has been established by a body which is a signatory to the ENEC Agreement.

TÜV Rheinland InterCert Kft., MEEI Division – Product Certification
H-1143 Budapest, Gizella út 51-57., Hungary
www.tuv.com

Tanúsító Szervezet
Certification Body

Eileen Feng

Validity of certificate can be checked on www.CERTIPEDIA.com

Annex to certificate No. HN 69291275 0001

Page 1/1

Model No.	Rated input	Rated input current (A)	Rated output voltage (Vd.c.)	No load voltage (Vd.c.)	Rated output current (A)	Pout (Max. W)	ta/ tc(°C)
DL-50Z-58A-MAL	100-277V~ 50/60Hz	0.60	32-58	75	0.5-1.2	50	55/90
DL-50Z-58S-MAL							
DL-60Z-58A-MAL	100-277V~ 50/60Hz	0.77	32-58	75	0.86-1.43	60	55/90
DL-60Z-58S-MAL							

A in model name indicates products can be change the output current via the adjusted button.
S in model name indicates products have three types of dimming function: 1-10V dimming, PWM dimming and resistance dimming. can be change the output current via the adjusted button.


TÜVRheinland

Date of issue:
Budapest, 2024-07-10

Certification Body**Eileen Feng**