

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

LED Driver

Name and address of the applicant

Guangdong Done Power Technology Co.,Ltd.
No.3-1&3-2, Kanglong 3rd Road, Henglan Town, Zhongshan,
528478 Guangdong
P.R. China

Name and address of the manufacturer

Guangdong Done Power Technology Co.,Ltd.
No.3-1&3-2, Kanglong 3rd Road, Henglan Town, Zhongshan,
528478 Guangdong
P.R. China

Name and address of the factory

Note: When more than one factory, please report on page 2

Guangdong Done Power Technology Co.,Ltd.
No.3-1&3-2, Kanglong 3rd Road, Henglan Town, Zhongshan,
528478 Guangdong
P.R. China

Ratings and principal characteristics

AC Input : 1)2)100-277V, 50/60Hz, 1.7A;
3)4)100-277V, 50/60Hz, 2.7A; Class I
DC Output: 1)180-260V, 0.25-0.60A, 120W Max.
2)180-260V, 0.40-0.75A, 150W Max.
3)180-260V, 0.55-1.05A, 200W Max.
4)180-260V, 0.75-1.15A, 240W Max.

Trademark / Brand (if any)

DONE

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

1) DL-120Z-260z-PXG, 2) DL-150Z-260z-PXG,
3) DL-200Z-260z-PXG, 4) DL-240Z-260z-PXG
(z = A, S, X, CX or U)

Additional information (if necessary may also be reported on page 2)

For model differences, refer to the test report.

A sample of the product was tested and found to be in conformity with

IEC 61347-2-13:2014+A1
IEC 61347-1:2015+A1

As shown in the Test Report Ref. No. which forms part of this Certificate

CN24I6AQ 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland Japan Ltd.
4-25-2 Kita-Yamata, Tsuzuki-ku
Yokohama 224-0021, Japan
Mail: info@jpn.tuv.com

Date: 2024-06-13

Signature:

Martin Wang